

Name Plate		
Ambient temperature	89.4	86.0%
Unit 1	Living Area	
Model	48204-666	
Compr. LRA (Amps)	60	
Compr. RLA (Amps)	10.9	
Fan FLA	2.8	
Compr. Cap	70mf +/- 5%	
Fan Cap	7.5mf +/- 5%	

Air filter	Cleaned
Delta T 30 Min >15	84.9-68.5
Compressor Run	13.21
Fan Run Hi	2.88
Fan Run Lo	2.58
Air Duct	Taped
Roof Seal	Good
shroud Damage	None
Evap Coil Clean	Cleaned/Good
Compressor Coil Clean	Cleaned
Drain Hole	Clean
Cap Comp	67.91mf
Cap Fan	7.54mf

Unit 2	Bedroom
Model	48204-666
Compr. LRA (Amps)	60
Compr. RLA (Amps)	10.9
Fan FLA	2.8
Compr. Cap	70mf +/- 5%
Fan Cap	7.5mf +/- 5%

Air filter	Cleaned
Delta T 30 Min >15	85.5-66.4
Compressor Run	12.31
Fan Run Hi	2.91
Fan Run Lo	2.69
Air Duct	Dump
Roof Seal	Good
shroud Damage	None
Evap Coil Clean	Clean/Good
Compressor Coil Clean	Clean/Good
Drain Hole	Clean
Cap Comp	70.22mf
Cap Fan	7.29mf



This document was created with the Win2PDF "Print to PDF" printer available at

<https://www.win2pdf.com>

This version of Win2PDF 10 is for evaluation and non-commercial use only.

Visit <https://www.win2pdf.com/trial/> for a 30 day trial license.

This page will not be added after purchasing Win2PDF.

<https://www.win2pdf.com/purchase/>